

R203 Permit Messages For Permit (1741632-0)

Event ID	Inspection	Inspection Date	Status
Structural Inspection			
388495	Final Building	1/10/2024	Pass Partial
	: Junction plates installed correctly to ½ of the Rack system. Tie down brackets out of stock		
390255	Final Building	1/23/2024	Pass
Electrical Inspection			
400011	Service Change	3/19/2024	Pass
399711	Underground Electrical	3/13/2024	Pass
	PVC conduits are greater than 24" below grade on driveway.		